

on Authorized Public Agency Procedures Manual, 2018 (MACDC)

on file at the Drain Office.

printing to 11x17



Inlet of new 8-inch PVC outlet, with trash rack



Discharge into MH #2

Open Drains

Storm Drains (Others)



Low flow channel connecting FES #1 to new outlet



Notes.

- 1. Existing outlet installed in 1993 as a combination inlet/outlet pipe with a 6-inch restricted outlet within MH #1. Due to clogging issues, a new 34 LFT of 8-inch SDR-26 PVC outlet installed and connected to MH #2.
- 2. Low flow channel graded between FES #1 and 8-inch outlet.
- 3. Elevations noted based on 1993 construction drawing datum

